



VISUAL STANDARD

COSHH Storage



KEY POINTS

- Sufficient bund for contained liquids to 110%
- All storage containers sufficient and marked correctly as classification, labelling and packaging 2015
- Locked and secured
- Protected from elements, Water causes and drains
 - Solid bases
 - Roofs
- Sufficient Spill and emergency equipment with competent persons to use it.
- Preventive controls identified on RAMs
- Hazardous waste segregated